



# HYBRID GENSET REPORT HAC15K



2022-09-12 to 2022-10-03

## Breakdown of Savings in Engine Hours and Fuel



Fuel costs saved  
\$ 2.609,17

CO<sub>2</sub> savings  
3360.1 kg

### Generator run times

Start	Stop	HH:MM	Litres consumed
2022-09-12 16:29	2022-09-13 02:25	09:54	26,7
2022-09-13 06:10	2022-09-13 11:46	05:36	15,1
2022-09-14 01:38	2022-09-14 05:10	03:30	9,5
2022-09-15 13:20	2022-09-15 13:42	00:24	1,1
2022-09-15 13:52	2022-09-15 14:26	00:36	1,6
2022-09-20 15:01	2022-09-20 15:27	00:24	1,1
2022-09-21 04:57	2022-09-21 05:20	00:24	1,1
2022-09-21 05:25	2022-09-21 06:50	01:24	3,8
2022-09-21 07:03	2022-09-21 07:50	00:48	2,2
2022-09-21 11:19	2022-09-21 11:55	00:36	1,6
2022-09-22 12:50	2022-09-22 20:54	08:06	21,9
2022-09-23 13:49	2022-09-23 18:26	04:36	12,4
2022-09-23 18:29	2022-09-23 20:07	01:36	4,3
2022-09-26 18:46	2022-09-26 21:47	03:00	8,1
2022-09-27 04:12	2022-09-27 07:13	03:00	8,1
2022-09-28 08:54	2022-09-28 10:03	01:12	3,2
2022-09-28 11:47	2022-09-28 12:28	00:42	1,9
2022-09-28 14:15	2022-09-28 16:16	02:00	5,4
2022-09-30 13:40	2022-09-30 14:31	00:54	2,4
2022-09-30 14:32	2022-09-30 15:25	00:54	2,4
2022-09-30 15:26	2022-09-30 15:51	00:24	1,1
2022-10-03 03:16	2022-10-03 06:44	03:30	9,5
<b>Total running time</b>		<b>56:36</b>	
	<b>Total use</b>		<b>151,2</b>



**1300 BROOKS** (1300 276 657)  
 sales@brookssiteservices.com.au  
**www.brookshire.com.au**